

**DUE TO EXPANSIVE SOIL, THE TOWN
OF CARRBORO RECOMMENDS ALL
FOOTINGS BE 24" WIDE X 12"
DEEP WITH TWO #4 REBAR**

CARRBORO INSPECTIONS

**PLEASE FURNISH MANUFACTURERS
SPECIFICATIONS ON WINDOW
AND DOOR FLASHING PRIOR
TO FRAMING INSPECTION**

CARRBORO INSPECTIONS

**ALL FOOTINGS MUST BE
24" WIDE x 12" DEEP WITH
TWO #4 REBAR**

CARRBORO INSPECTIONS